



MECHANICAL KEYED NOTES

- ① CONTRACTOR SHALL BLOCK THE EXISTING RETURN LEG OF THE THREE WAY VALVE TO CREATE A TWO-WAY FLOW PATTERN THROUGH THE VALVE.
- ② EXISTING VALVE SHALL CONTINUE TO OPERATE AS A 3-WAY VALVE TO ALLOW MINIMUM REQUIRED FLOW THROUGH THE SYSTEM AT ALL TIMES.

DATE	REVISION DESCRIPTION	ISSUED FOR
11/18/10		

CHILLER REPLACEMENT PROJECT
 MHMRA BUILDING, 7011 SW FREEMWAY
 HOUSTON, TX

REDDING
 LINDEN
 BURR
 CONSULTING ENGINEERS
 801 TRAVIS, SUITE 2000
 HOUSTON, TEXAS 77002
 TEL: 713.227.9800
 FAX: 713.227.9801
 WWW.RLEENGINEERS.COM
 Texas Registered Engineering Firm F-1113

DATE: 11/18/2010
 PROJECT #: 10100.00
 SHEET # ME-2.20

1 REVISED CHILLED WATER DISTRIBUTION RISER
 SCALE: NO SCALE